



The Commonwealth of Massachusetts
 Executive Office of Health and Human Services
 Department of Public Health
 Bureau of Environmental Health
 Community Sanitation Program
 5 Randolph Street, Canton, MA 02021
 Phone: 781-828-7700 Fax: 781-828-7703

CHARLES D. BAKER
 Governor

KARYN E. POLITO
 Lieutenant Governor

MARYLOU SUDDERS
 Secretary

MONICA BHAREL, MD, MPH
 Commissioner

Tel: 617-624-6000
www.mass.gov/dph

April 10, 2015

Michael Corsini, Superintendent
 M.C.I. Plymouth
 Myles Standish State Forest
 South Carver, MA 02366

Re: Facility Inspection - M.C.I. Plymouth, Carver

Dear Superintendent Corsini:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, as well as Massachusetts Department of Public Health (Department) Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; 105 CMR 520.000 Labeling; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the M.C.I. Plymouth on March 31, 2015 accompanied by Matt Rose, EHSO. Violations noted during the inspection are listed below including 10 repeat violations:

HEALTH AND SAFETY VIOLATIONS

(* indicates conditions documented on previous inspection reports)

Central Control

Lobby

No Violations Noted

Office

No Violations Noted

Break Room

FC 4-204.112(A)
 FC 3-304.12(A)

Design and Construction, Functionality: No functioning thermometer in grey refrigerator
 Preventing Contamination from Utensils: Service utensils handle stored below the food and container line, scoop stored in sugar

Staff Bathroom

No Violations Noted

Medical Exam Room

No Violations Noted

Medical Office

No Violations Noted

A Dorm

Inmate Break Room

No Violations Noted

Bathroom

105 CMR 451.123*
105 CMR 451.123

Maintenance: Radiator paint peeling
Maintenance: Soap dispenser missing at handwash sink

Showers

105 CMR 451.123*
105 CMR 451.130
105 CMR 451.123

Maintenance: Ceiling vent dusty in shower area
Plumbing: Plumbing not maintained in good repair, shower leaking in handicap shower
Maintenance: Soap scum on walls in shower # 2 on right

Mop Room

105 CMR 451.353*

Interior Maintenance: Radiator damaged

Bunks

105 CMR 451.320*

Cell Size: Inadequate floor space in all cells

B Dorm

Barbershop

105 CMR 451.126

Hot Water: Hot water temperature recorded at 71⁰F

Inmate Break Room

No Violations Noted

Hallway

No Violations Noted

Bathroom

105 CMR 451.123
105 CMR 451.123

Maintenance: Soap dispenser missing at handwash sink
Maintenance: Wet mop stored in bucket

Showers

105 CMR 451.123
105 CMR 451.123

Maintenance: Light out outside shower # 3
Maintenance: Radiator paint peeling

Mop Room

No Violations Noted

Bunks

105 CMR 451.320*
105 CMR 451.103

Cell Size: Inadequate floor space in all cells
Mattresses: Mattress damaged in cell # 201, 202, and 243

C Dorm (Offices and Dog Area)

Staff Male Bathroom

No Violations Noted

Staff Female Bathroom

No Violations Noted

Laundry Room

No Violations Noted

Inmate Bathroom

105 CMR 451.123
105 CMR 451.123

Maintenance: Missing ground prong on fan plug
Maintenance: Wet mop stored in bucket

Showers

105 CMR 451.130*
105 CMR 451.123

105 CMR 451.123

Plumbing: Plumbing not maintained in good repair, shower # 5 on left leaking
Maintenance: Shower rusted at bottom in shower # 1, 3, and 5 on left and # 1, 2, and 3 on right
Maintenance: Soap scum on walls in all showers

Mop Closet

105 CMR 451.353*

Interior Maintenance: Wet mop stored in bucket

Inmate Break Room

No Violations Noted

Cells

105 CMR 451.320*

Cell Size: Inadequate floor space in cell # 303 and 306 – 325

Urinalysis Room

No Violations Noted

Copy Room/Break Room

FC 7-206.12

Poisonous or Toxic Materials; Pesticides: Rodent traps not covered near microwave

Superintendent's Office

No Violations Noted

Day Room

No Violations Noted

Classification Area

Unable to Inspect – Meeting

Food Service

Dining Room

FC 6-501.11

Maintenance and Operation; Repairing: Facility not in good repair, light out

Inmate Bathroom

FC 5-202.12(A)*
FC 6-501.11*

Plumbing System, Design: Handwashing sinks water temperature recorded at 82°F
Maintenance and Operation; Repairing: Facility not in good repair, radiator damaged

Visitor's Bathroom

No Violations Noted

Kitchen

3-Bay Sink Area

FC 4-501.114(A)

Maintenance and Operation; Equipment: Chlorine Sanitizer solution tested greater than recommended concentration

Walk-In Refrigerator

No Violations Noted

Walk-In Freezer

FC 6-201.11

Design, Construction and Installation: Floor not easily cleanable, floor damaged at the entrance to freezer

Dishwasher Machine Area

FC 6-501.11

Maintenance and Operation; Repairing: Facility not in good repair, chemical sanitizer not dispensing in dishwashing machine

Dry Storage

No Violations Noted

Toxic/Caustic Room

No Violations Noted

Toxic/Caustic Area

No Violations Noted

Officer's Room

FC 6-501.11

Maintenance and Operation; Repairing: Facility not in good repair, ceiling leaking

Exterior Buildings

Morton Building

Main Area

No Violations Noted

Freezer # 1

No Violations Noted

Freezer # 2

No Violations Noted

Day Room

105 CMR 451.353

Interior Maintenance: Wall paint peeling

Property Room

No Violations Noted

Laundry

No Violations Noted

Library

No Violations Noted

Weight Room

105 CMR 451.350*

Structural Maintenance: Doors not rodent and weathertight

Bunk House

No Violations Noted

Staff Bathroom

No Violations Noted

No Violations Noted

Observations and Recommendations

1. The inmate population was 192 at the time of inspection.
2. During the inspection, the Department recommended that all showers and cells be identified with a numbering system. This will assist the Department and correctional employees to better recognize where issues exist.

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice, indicating the specific corrective steps to be taken, a timetable for such steps, and the date by which correction will be achieved. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

To review the Labeling regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "General Food Regulations" click "105 CMR 520.000: Labeling."

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Nicholas Gale
Environmental Health Inspector, CSP, BEH

cc: Suzanne K. Condon, Associate Commissioner, Director, BEH
Steven Hughes, Director, CSP, BEH
Jay Youmans, Director of Government Affairs
Marylou Sudders, Secretary, Executive Office of Health and Human Services
Carol Higgins O'Brien, Commissioner, DOC
Matt Rose, EHSO
Michelle Roberts, MA, CHO, Health Director, Plymouth Health Department
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Daniel Bennett, Secretary, EOPS