



CHARLES D. BAKER
GOVERNOR

JOHN C. CHAPMAN
UNDERSECRETARY OF
CONSUMER AFFAIRS AND
BUSINESS REGULATION

KARYN E. POLITO
LIEUTENANT GOVERNOR

Commonwealth of Massachusetts
Division of Professional Licensure
Office of Public Safety and Inspections
Architectural Access Board

CHARLES BORSTEL
COMMISSIONER, DIVISION OF
PROFESSIONAL LICENSURE

JAY ASH
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

THOMAS HOPKINS
EXECUTIVE DIRECTOR

1 Ashburton Place, Rm 1310 Boston Massachusetts 02108
V: 617-727-0660 www.mass.gov/aab Fax: 617-727-0665

Docket Number V 17 063

NOTICE OF ACTION

RE: Three Location along Main Street, Inter North Street to South Street

Ware

1. A request for a variance was filed with the Board by John G. Morgan Jr.
The applicant has requested variances from the following sections of the

(Applicant) on March 24, 2017

06 Rules and Regulations of the Board:

<u>Section:</u>	<u>Description:</u>
22.3.1	Petitioner seeks relief for the cross slope at three (3) locations within the project work area. The proposed slope for those locations is reported to be 6.8%

2. The application was heard by the Board as an incoming case on Monday, April 10, 2017

3. After reviewing all materials submitted to the Board, the Board voted as follows:

CONTINUE: the case so that the petitioners designer can provide a new sloped design for the sidewalk. The design should show 2% from the face of building. Creating a path of travel as wide as possible with the steep slope relegated to the furniture zone along the curb line. The Board will grant relief for the slope in the furniture zone.

Please provide the new plan for the Board to review at your earliest convenience.

PLEASE NOTE: All documentation (written and visual) verifying that the conditions of the variance have been met must be submitted to the AAB Office as soon as the required work is completed.

Any person aggrieved by the above decision may request an adjudicatory hearing before the Board within 30 days of receipt of this decision by filing the attached request for an adjudicatory hearing. If after 30 days, a request for an adjudicatory hearing is not received, the above decision becomes a final decision and the appeal process is through Superior Court.

Date: April 12, 2017

cc: Local Disability Commission
Local Building Inspector
Independent Living Center

Walter White T.H.
Chairperson
ARCHITECTURAL ACCESS BOARD