



CHARLES D. BAKER  
GOVERNOR

KARYN E. POLITO  
LIEUTENANT GOVERNOR

JAY ASH  
SECRETARY OF HOUSING AND  
ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts  
Division of Professional Licensure  
Office of Public Safety and Inspections  
Architectural Access Board

1 Ashburton Place, Rm 1310 Boston Massachusetts 02108  
V: 617-727-0660 www.mass.gov/aab Fax: 617-727-0665

JOHN C. CHAPMAN  
UNDERSECRETARY OF  
CONSUMER AFFAIRS AND  
BUSINESS REGULATION

CHARLES BORSTEL  
COMMISSIONER, DIVISION OF  
PROFESSIONAL LICENSURE

THOMAS HOPKINS  
EXECUTIVE DIRECTOR

AMENDED NOTICE OF ACTION

Docket Number **V17 052**

RE: Flynn Rink

, 300 Elm Street , Medford

An application for variance was filed with the Board by Robert W. Decker (Applicant) on March 3, 2017

The applicant has requested variances from the following sections of the 2006 Rules and Regulations of the Board:

Section: Description:

6.3 In team rooms 5& 6 there is a 7' foot clear turning diameter. However when hockey bags are on the floor the inspector is concerned that the radius will be under 5' feet diameter required. The rink will make accommodations for this issue by using team room 1 thru 4 which are fully accessible.

19.4.2 See above

On August 1, 2017 John S. MacDonald wrote to the Board and provided a response to Docket Number V17-052. The architect provided a written policy on the use of the locker rooms and a handicapped access statement (accommodation policy) on how access is provided. In addition, a drawing which depicts the identification signage that is provided at the accessible locker room, See SK\_01 dated August 1, 2017.

2. The submittal was reviewed by the Board on Monday, August 7, 2017
3. After reviewing all materials submitted to the Board, the Board voted as follows:

The Board voted that no variance requests to Sections 6.3, 19.4.2, and 26.5 as submitted in the application were needed at this time.

In addition, the Board voted to **ACCEPT** the signage design and written document "Flynn Rink Locker Room Policies."

Any person aggrieved by the above decision may request an adjudicatory hearing before the Board within 30 days of receipt of this decision by filing the attached request for an adjudicatory hearing. If after 30 days, a request for an adjudicatory hearing is not received, the above decision becomes a final decision and the appeal process is through Superior Court.

cc: Local Building Inspector, Local Disability Commission,  
Independent Living Center

Chairperson, Architectural Access Board

Date: April 18, 2017