



CHARLES D. BAKER
GOVERNOR

KARYN E. POLITO
LIEUTENANT GOVERNOR

JAY ASH
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts
Division of Professional Licensure
Office of Public Safety and Inspections
Architectural Access Board

JOHN C. CHAPMAN
UNDERSECRETARY OF
CONSUMER AFFAIRS AND
BUSINESS REGULATION

CHARLES BORSTEL
COMMISSIONER, DIVISION OF
PROFESSIONAL LICENSURE

THOMAS HOPKINS
EXECUTIVE DIRECTOR

1 Ashburton Place, Rm 1310 Boston Massachusetts 02108
V: 617-727-0660 www.mass.gov/aab Fax: 617-727-0665

AMENDED NOTICE OF ACTION

Docket Number **V18 243**

RE: Walpole Police Headquarters, 50 South Street, Walpole

An application for variance was filed with the Board by Krystal R. Burrows (Applicant) on July 20, 2018.

The applicant has requested variances from the following sections of the 2006 Rules and Regulations of the Board:

Section: Description:

23.4.3 Petitioner seeks relief for a portion of a parking space with a slope of greater than 2% but less than 3%.

22.3 Petitioner seeks relief for a walkway with a running slope of greater than 5% The walkway running slope is reported to measure 6% to 7%.

2. The submittal was reviewed by the Board on Monday, October 29, 2018
3. After reviewing all materials submitted to the Board, the Board voted as follows:

GRANT: the variance to Section 23.4.3, 22.3, and 21.3 **as proposed** in the application submitted, for the reason that impracticability (see definitions of impracticability in Section 5 of 521 CMR) has been proven in this case and on the condition that:

1. handrails are provided in accordance with 521 CMR Section 24 et al for that portion of the walkway which exceeds 5%. (see plans and photographic exhibits submitted) Side walk slope reported to be measured at 6% to 7%.
2. photographs of the completed handrail work are required for the Boards file on V18 - 243.

Note: the meeting that had been scheduled for Monday November 5, 2018 at 10:AM with Krystal R. Burrows and the architect of record is no longer needed. A meeting cancellation e-mail was sent on Wednesday October 31, 2018 at 1:48 P.M. (e-mail attached)

Any person aggrieved by the above decision may request an adjudicatory hearing before the Board within 30 days of receipt of this decision by filing the attached request for an adjudicatory hearing. If after 30 days, a request for an adjudicatory hearing is not received, the above decision becomes a final decision and the appeal process is through Superior Court.

cc: Local Building Inspector, Local Disability Commission,
Independent Living Center

Chairperson, Architectural Access Board

Date: August 14, 2018