



CHARLES D. BAKER
GOVERNOR

JOHN C. CHAPMAN
UNDERSECRETARY OF
CONSUMER AFFAIRS AND
BUSINESS REGULATION

KARYN E. POLITO
LIEUTENANT GOVERNOR

Commonwealth of Massachusetts
Division of Professional Licensure
Office of Public Safety and Inspections
Architectural Access Board

CHARLES BORSTEL
COMMISSIONER, DIVISION OF
PROFESSIONAL LICENSURE

JAY ASH
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

THOMAS HOPKINS
EXECUTIVE DIRECTOR

1 Ashburton Place, Rm 1310 Boston Massachusetts 02108
V: 617-727-0660 www.mass.gov/aab Fax: 617-727-0665

Docket Number V 18 243

NOTICE OF ACTION

RE: **Walpole Police Headquarters, 50 South Street**

Walpole

1. A request for a variance was filed with the Board by Krystal R. Burrows (Applicant) on July 20, 2018
The applicant has requested variances from the following sections of the 06 Rules and Regulations of the Board:

<u>Section:</u>	<u>Description:</u>
23.4.3	Petitioner seeks relief for a portion of a parking space with a slope of greater than 2%
22.3	Petitioner seeks relief for a walkway with a slope of greater than 5%
21.3	Petitioner seeks relief for a curb cut with a running slope of greater than 8.3%

- The application was heard by the Board as an incoming case on Monday, August 13, 2018
- After reviewing all materials submitted to the Board, the Board voted as follows:

CONTINUE the requests for relief from 23.4.3, 22.3, & 21.3 for additional information on:

- The slope of the area of the parking space where relief is requested,
- Details on which curb cut is the subject of the variance including a diagram or table specifying where each slope measurement was taken along the ramp run,
- Details on which portion of walkway is the subject of the variance and a diagram or table specifying where each slope measurement was taken along the walkway, and
- Proof of service of the application and all attached documents to the Boston Center for Independent Living as required by Instruction 6c on the Application for Variance.

PLEASE NOTE: All documentation (written and visual) verifying that the conditions of the variance have been met must be submitted to the AAB Office as soon as the required work is completed.

Any person aggrieved by the above decision may request an adjudicatory hearing before the Board within 30 days of receipt of this decision by filing the attached request for an adjudicatory hearing. If after 30 days, a request for an adjudicatory hearing is not received, the above decision becomes a final decision and the appeal process is through Superior Court.

Date: August 14, 2018

cc: Local Disability Commission
Local Building Inspector
Independent Living Center

Chairperson
ARCHITECTURAL ACCESS BOARD